

# CITY OF HIGH POINT

## AGENDA ITEM



<b>TITLE:</b> Alum Sludge Dewatering- Ward Water Treatment Plant American Process Group, LLC	
<b>FROM:</b> Robby Stone – Public Services Director Derrick Boone – Asst. Public Services Director	<b>MEETING DATE:</b> May 6, 2024
<b>PUBLIC HEARING:</b> N/A	<b>ADVERTISED DATE/BY:</b> February 7, 2024 Purchasing Department
<b>ATTACHMENTS:</b> Bid Tabulation	

**PURPOSE:** To hire a contractor to dredge and dewater the contents of the Ward Treatment Plant's southern alum sludge lagoon. The material will be removed by the Contractor, hauled to a regulatory approved designated disposal area, and properly disposed of per State Requirements. The estimated quantity to be removed is 1,400 dry tons.

**BACKGROUND:** Aluminum Sulfate is used at the Ward Water Plant for coagulation as part of the water treatment process. The sediment and pollutants that are removed as part of the treatment process are transferred to the lagoons at the Ward Water Plant. The contents of the lagoons must be dredged, dewatered, and disposed of periodically.

A total of five (5) bids were received and the lowest bidder was deemed non-responsive. The next lowest responsive responsible bidder is American Process Group, LLC in the amount of \$885,773.

**BUDGET IMPACT:** Funds for this project are available in the FY 2023-2024 Budget.

**RECOMMENDATION/ACTION REQUESTED:** The Public Services Department recommends awarding the contract to American Process Group, LLC in the amount of \$885,773 and authorize appropriate City Official(s) to execute all necessary documents.





South Lagoon at the Ward Water Treatment Plant

**Bid Tabulation  
City of High Point, North Carolina  
Alum Sludge Dewatering  
Bid 32-032024**

<b>Contractor</b>	<b>MWBE</b>	<b>Addendum 1</b>	<b>Total Bid</b>
Spectrum Biotechnologies*	Yes	Yes	\$813,700.00
<b>American Process Group</b>	<b>Yes</b>	<b>Yes</b>	<b>\$885,773.00</b>
Eagle Dynamic Solutions	Yes	Yes	\$963,150.00
P&H Senesac	No	No	\$1,009,716.00
Bio-Nomic Services	Yes	Yes	\$1,472,208.00

\*Bid Deemed Non-Responsive, unable to meet 18% Dryness Requirement \*