

CITY OF HIGH POINT

AGENDA ITEM



Title: Eastside WWTP Safety Improvements

From: Terry Houk – Public Services Director

Derrick Boone – Public Services Asst. Director

James Gwyn – Safety Officer

Meeting Date: September 18, 2017

Public Hearing: N/A

Advertising Date: July 21, 2017

Advertised By: Purchasing

Attachments: Attachment A – Bid Tabulations

PURPOSE:

The Public Services Department has identified the need for safety improvements at the Eastside Wastewater Treatment Plant (WWTP.)

BACKGROUND:

A safety inspection of the Eastside WWTP performed by Safety and Health in 2015 found that additional safety showers/eyewashes, sky-light covers and fall protection tie-offs were required to meet current OSHA standards. Public Services selected an engineering firm for design and bidding purposes. The bids received in 2016 exceeded amount allocated in the operational budget. Public Services then budgeted for this project in Capital Improvement Plan.

BUDGET IMPACT:

Funds for this project are available in the 2017-2018 Budget.

RECOMMENDATION / ACTION REQUESTED:

The Public Services Department recommends approval and asks for the Council to award the project to Isley Construction, for \$184,624.00.



**FORMAL BID RECOMMENDATION
REQUEST FOR COUNCIL APPROVAL**

DEPARTMENT: **Public Services**

COUNCIL AGENDA DATE: **Sep 18, 2017**

BID NO.: **05-083017**

CONTRACT NO.:

DATE OPENED: **August 30/17**

DESCRIPTION:

Eastside Wastewater Treatment Plant Safety Improvements

PURPOSE:

The City has budgeted to install safety showers, eyewashes and fall protection at Eastside wastewater treatment plant.

COMMENTS:

These are required to meet current OSHA safety rules.

RECOMMEND AWARD TO: **Isley Construction**

AMOUNT: **\$184,624.00**

JUSTIFICATION:

Isley Construction was the lowest of the three qualified bids.

ACCOUNTING UNIT	ACCOUNT	ACTIVITY	CATEGORY	BUDGETED AMOUNT
421779	533701	421181028705	40202	\$184,624.00
TOTAL BUDGETED AMOUNT				\$184,624.00

DEPARTMENT HEAD: **Terry Houk**

Digitally signed by Terry Houk
DN: cn=Terry Houk, o=City of High Point, ou=Public Services, email=terry.houk@highpointnc.gov, c=US
Date: 2017.09.06 12:35:32 -0400

DATE: **Sep 6, 2017**

The Purchasing Division concurs with recommendation submitted by the **Public Services** and recommends award to the lowest responsible, responsive bidder **Isley Construction** in the amount of \$ **184,624.00**.

PURCHASING MANAGER: **Erik Conti**

Digitally signed by Erik Conti
DN: cn=Erik Conti, o, ou,
email=erik.conti@highpointnc.gov, c=US
Date: 2017.09.07 12:50:24 -0400

DATE: **Sep 7, 2017**

Approved for Submission to Council

FINANCIAL SERVICES DIRECTOR: 

Digitally signed by Jeffrey A. Moore
DN: cn=Jeffrey A. Moore, o=City of High Point, NC,
ou=Financial Services Director, email=jmoore@highpointnc.gov, c=US
Date: 2017.09.07 16:47:14 -0400

DATE: **Sep 7, 2017**

CITY MANAGER: **Greg Demko**

Digitally signed by Greg Demko
DN: cn=Greg Demko, o=High Point, ou=High Point,
email=greg.demko@highpointnc.gov, c=US
Date: 2017.09.11 09:34:30 -0400

DATE: **Sep 11, 2017**

**City of High Point, NC
Eastside WWTP Safety Improvements
Single Prime Contract 1**

BID TABULATION

**Bid Date: August 30, 2017
Bid Opening Time: 2:00 p.m.
Bid Number 05-083017**

Contractors:	License Number	Affidavit A or B and H	Bid Security	Lump Sum Bid Amount	Deductive Alternate Item 2A Effluent Pump Building Ladder Tie-Off	Deductive Alternate Item 2B NRCY Pump Station Tie-off Posts	Additive Alternate Item 3 Roof Access Fall Protection Skylight Screens
ASJ Wilson Construction	65796	Y	Y	\$464,072.00	\$7,500.00	\$4,250.00	\$27,200.00
A Vogt Construction	73557	Y	Y	\$300,000.00	\$7,000.00	-	\$20,314.00
Isley Construction	28356	Y	Y	\$170,000.00	\$3,000.00	\$4,745.00	\$14,624.00

CERTIFICATION

The bids tabulated herein were opened and read aloud at 2:00 p.m. on the 30th day of August, 2017 at the Municipal Office Building in the City of High Point, NC. The tabulation is correct in that it lists the Bid Item Amounts and the Lump Sum Base Bid Amount as presented in the original price proposals from each bidder.

Hazen

Hazen and Sawyer
629 Green Valley Rd, Suite 200
Greensboro, NC 27403
336.292.7490
Ruth S. Borgmann, P.E.
Principal Engineer

