

CITY OF HIGH POINT

AGENDA ITEM



Title: Riverdale Pump Station Emergency Generator

From: Terry Houk – Public Services Director
Derrick Boone – Public Services Asst. Director

Meeting Date: March 4, 2019

Public Hearing: N/A

Advertising Date: N/A

Advertised By: N/A

Attachments: Quote

PURPOSE:

To expand the capacity of the Riverdale Lift Station while an emergency bypass is in place to repair the station from flooding that occurred during Hurricane Florence.

BACKGROUND:

The City of High Point transfers wastewater flow to the Eastside WWTP via the Riverdale Pump Station from areas located on the north side of the city. This is the City's largest pump station. During Hurricane Florence, the pump station flooded resulting in damage to three (3) pumps. While still under the emergency bypass, the Public Services is expanding the Riverdale Lift Station. The expansion will include a 10 MGD submersible pump and a second force main that will discharge to the Eastside Wastewater Treatment Plant. As part of this expansion emergency backup power is required.

Cummins Sales and Service is on the Sourcewell (NJPA) National Cooperative Contract (#120617-CMM) and as such the City may purchase directly from this company without obtaining quotes and/or Bids. This situation has also been declared a pressing need per the purchasing manager.

BUDGET IMPACT:

Funds for this project are available in the 2018-2019 Budget.

RECOMMENDATION / ACTION REQUESTED:

The Public Services Department recommends approval of the quote submitted by Cummins Sales and Service for an emergency generator in the amount of \$143,485.00.