

City of High Point

Municipal Office Building 211 S. Hamilton Street High Point, NC 27260

Legislation Text

File #: 2019-300, Version: 1

Contract - A&D Environmental Services Inc-Eastside Wastewater Treatment Plant Primary Clarifiers

Council requested to approve an emergency purchase order in the amount of \$186,476.99 to utilize A&D Environmental Services Inc. to remove a significant amount of grit & grease from the primary clarifiers due to a June 7-8, 2019 rain event at the Eastside WWTP, causing grit and grease to clog the primary sludge pumps and four (4) primary clarifiers.

[Enter body here.]